


Instrument name: Testo				5.12.2024	
Start time: 4.12.2024 20.20.56		Minimum	Maximum	Mean value	Limit values
End time: 5.12.2024 13.03.56	BT25 MLP:ltä [°C]	32,8	68,3	57,635	-195,0/1000,0
Measurement channels: 4	BT3 paluu varaajalta	30,9	56,7	52,568	-195,0/1000,0
Measured values: 1004	T ulkolämpötila [°C]	-8,9	-1,5	-7,156	-195,0/1000,0
SN 40725629	Patteriverkko menov	36,2	43,0	39,603	-195,0/1000,0
Lämpötilat MLP					



ID	Date/time	BT25 MLP:ltä [°C]	BT3 paluu varaajalta MLP:hen [°C]	T ulkolämpötila [°C]	Patteriverkko menovesi [°C]
1	4.12.2024 20.20.56	68.3	32.8	-7.5	39.7
2	4.12.2024 20.21.56	68.2	32.7	-7.5	39.7
3	4.12.2024 20.22.56	68.2	32.7	-7.4	39.8
4	4.12.2024 20.23.56	68.2	32.7	-7.5	39.8
5	4.12.2024 20.24.56	68.1	32.6	-7.5	39.8
6	4.12.2024 20.25.56	68.1	32.6	-7.6	39.8
7	4.12.2024 20.26.56	68.1	32.6	-7.6	39.8
8	4.12.2024 20.27.56	68.0	32.5	-7.6	39.8
9	4.12.2024 20.28.56	68.0	32.5	-7.7	39.9
10	4.12.2024 20.29.56	68.0	32.4	-7.7	39.9
11	4.12.2024 20.30.56	67.9	32.4	-7.6	39.9
12	4.12.2024 20.31.56	67.9	32.4	-7.5	39.9

ID	Date/time	BT25 MLP:ltä [°C]	BT3 paluu varaajalta MLP:hen [°C]	T ulkolämpötila [°C]	Patteriverkko menovesi [°C]
13	4.12.2024 20.32.56	67.8	32.4	-7.5	39.9
14	4.12.2024 20.33.56	67.8	32.4	-7.5	39.9
15	4.12.2024 20.34.56	67.7	32.3	-7.4	39.8
16	4.12.2024 20.35.56	67.7	32.3	-7.4	39.8
17	4.12.2024 20.36.56	67.7	32.3	-7.4	39.8
18	4.12.2024 20.37.56	67.7	32.2	-7.5	39.8
19	4.12.2024 20.38.56	67.6	32.2	-7.4	39.8
20	4.12.2024 20.39.56	67.6	32.2	-7.4	39.7
21	4.12.2024 20.40.56	67.6	32.2	-7.5	39.7
22	4.12.2024 20.41.56	67.5	32.2	-7.4	39.7
23	4.12.2024 20.42.56	67.5	32.1	-7.5	39.7
24	4.12.2024 20.43.56	67.4	32.1	-7.5	39.7
25	4.12.2024 20.44.56	67.4	32.1	-7.4	39.7
26	4.12.2024 20.45.56	67.3	32.1	-7.5	39.6
27	4.12.2024 20.46.56	67.3	32.1	-7.3	39.6
28	4.12.2024 20.47.56	67.3	32.0	-7.3	39.5
29	4.12.2024 20.48.56	67.3	32.0	-7.4	39.5
30	4.12.2024 20.49.56	67.2	32.0	-7.4	39.4
31	4.12.2024 20.50.56	67.2	32.0	-7.5	39.4
32	4.12.2024 20.51.56	67.2	31.9	-7.6	39.4
33	4.12.2024 20.52.56	67.1	31.9	-7.6	39.3
34	4.12.2024 20.53.56	67.1	31.9	-7.5	39.3
35	4.12.2024 20.54.56	67.1	31.8	-7.4	39.3
36	4.12.2024 20.55.56	67.0	31.8	-7.5	39.3
37	4.12.2024 20.56.56	67.0	31.8	-7.5	39.3
38	4.12.2024 20.57.56	67.0	31.8	-7.6	39.2
39	4.12.2024 20.58.56	67.0	31.7	-7.6	39.2
40	4.12.2024 20.59.56	66.9	31.7	-7.5	39.2
41	4.12.2024 21.00.56	66.9	31.7	-7.6	39.1
42	4.12.2024 21.01.56	66.9	31.7	-7.6	39.4
43	4.12.2024 21.02.56	66.8	31.7	-7.6	39.4
44	4.12.2024 21.03.56	66.8	31.6	-7.6	39.5
45	4.12.2024 21.04.56	66.8	31.6	-7.8	39.5
46	4.12.2024 21.05.56	66.8	31.6	-7.8	39.5
47	4.12.2024 21.06.56	66.7	31.6	-7.7	39.5
48	4.12.2024 21.07.56	66.7	31.5	-7.6	39.5
49	4.12.2024 21.08.56	66.7	31.5	-7.6	39.5
50	4.12.2024 21.09.56	66.6	31.5	-7.6	39.5
51	4.12.2024 21.10.56	66.6	31.5	-7.6	39.5
52	4.12.2024 21.11.56	66.6	31.5	-7.7	39.5
53	4.12.2024 21.12.56	66.5	31.5	-7.8	39.5
54	4.12.2024 21.13.56	66.5	31.4	-7.8	39.5
55	4.12.2024 21.14.56	66.5	31.4	-7.9	39.5
56	4.12.2024 21.15.56	66.4	31.4	-7.8	39.6

ID	Date/time	BT25 MLP:ltä [°C]	BT3 paluu varaajalta MLP:hen [°C]	T ulkolämpötila [°C]	Patteriverkko menovesi [°C]
57	4.12.2024 21.16.56	66.4	31.4	-7.8	39.6
58	4.12.2024 21.17.56	66.4	31.3	-7.8	39.4
59	4.12.2024 21.18.56	66.4	31.3	-7.9	39.3
60	4.12.2024 21.19.56	66.3	31.3	-8.0	39.3
61	4.12.2024 21.20.56	66.3	31.3	-8.0	39.4
62	4.12.2024 21.21.56	66.2	31.3	-8.1	39.4
63	4.12.2024 21.22.56	66.2	31.3	-8.1	39.4
64	4.12.2024 21.23.56	66.2	31.2	-8.1	39.4
65	4.12.2024 21.24.56	66.2	31.2	-7.6	39.4
66	4.12.2024 21.25.56	66.1	31.2	-7.9	39.4
67	4.12.2024 21.26.56	66.1	31.2	-7.9	39.4
68	4.12.2024 21.27.56	66.0	31.2	-7.9	39.4
69	4.12.2024 21.28.56	66.0	31.2	-7.8	39.4
70	4.12.2024 21.29.56	66.0	31.1	-7.9	39.4
71	4.12.2024 21.30.56	66.0	31.1	-7.9	39.4
72	4.12.2024 21.31.56	65.9	31.1	-8.0	39.4
73	4.12.2024 21.32.56	65.9	31.1	-8.0	39.4
74	4.12.2024 21.33.56	65.9	31.0	-8.0	39.4
75	4.12.2024 21.34.56	65.9	31.0	-8.0	39.5
76	4.12.2024 21.35.56	65.8	31.0	-8.0	39.5
77	4.12.2024 21.36.56	65.8	31.0	-8.0	39.4
78	4.12.2024 21.37.56	65.7	31.0	-8.1	39.4
79	4.12.2024 21.38.56	65.7	31.0	-8.1	39.4
80	4.12.2024 21.39.56	65.7	31.0	-8.1	39.4
81	4.12.2024 21.40.56	65.7	31.0	-8.0	39.4
82	4.12.2024 21.41.56	65.6	31.0	-8.1	39.4
83	4.12.2024 21.42.56	65.6	30.9	-8.0	39.4
84	4.12.2024 21.43.56	56.5	31.4	-8.0	39.4
85	4.12.2024 21.44.56	36.2	32.1	-8.0	39.4
86	4.12.2024 21.45.56	33.7	32.3	-8.1	39.4
87	4.12.2024 21.46.56	33.0	32.5	-8.1	39.4
88	4.12.2024 21.47.56	32.9	32.6	-8.1	39.4
89	4.12.2024 21.48.56	32.8	32.7	-8.1	39.4
90	4.12.2024 21.49.56	33.4	33.2	-8.1	39.4
91	4.12.2024 21.50.56	35.4	33.7	-8.1	39.3
92	4.12.2024 21.51.56	36.0	34.1	-8.2	39.3
93	4.12.2024 21.52.56	36.2	34.6	-8.1	39.3
94	4.12.2024 21.53.56	36.6	35.3	-8.1	39.3
95	4.12.2024 21.54.56	37.1	36.0	-8.2	39.3
96	4.12.2024 21.55.56	37.8	36.5	-8.2	39.3
97	4.12.2024 21.56.56	38.6	37.4	-8.3	39.2
98	4.12.2024 21.57.56	39.4	38.4	-8.1	39.2
99	4.12.2024 21.58.56	40.4	39.1	-8.2	39.4
100	4.12.2024 21.59.56	41.5	40.3	-8.1	39.6

ID	Date/time	BT25 MLP:ltä [°C]	BT3 paluu varaajalta MLP:hen [°C]	T ulkolämpötila [°C]	Patteriverkko menovesi [°C]
101	4.12.2024 22.00.56	42.7	40.9	-8.0	39.7
102	4.12.2024 22.01.56	43.8	41.8	-8.3	39.6
103	4.12.2024 22.02.56	44.9	43.0	-8.2	39.7
104	4.12.2024 22.03.56	46.2	44.1	-8.3	39.5
105	4.12.2024 22.04.56	47.5	45.4	-8.4	39.5
106	4.12.2024 22.05.56	48.7	47.1	-8.6	39.5
107	4.12.2024 22.06.56	50.3	49.4	-8.7	39.3
108	4.12.2024 22.07.56	52.3	51.3	-8.6	39.3
109	4.12.2024 22.08.56	54.5	52.0	-8.9	39.2
110	4.12.2024 22.09.56	56.3	52.9	-8.8	39.2
111	4.12.2024 22.10.56	57.8	53.7	-8.7	39.2
112	4.12.2024 22.11.56	58.9	53.8	-8.8	39.0
113	4.12.2024 22.12.56	59.5	54.0	-8.8	39.0
114	4.12.2024 22.13.56	60.1	53.9	-8.8	38.9
115	4.12.2024 22.14.56	60.5	54.3	-8.8	39.2
116	4.12.2024 22.15.56	60.9	54.4	-8.7	39.3
117	4.12.2024 22.16.56	61.1	54.4	-8.7	39.3
118	4.12.2024 22.17.56	61.2	54.5	-8.7	39.4
119	4.12.2024 22.18.56	61.3	54.5	-8.6	39.5
120	4.12.2024 22.19.56	61.4	54.4	-8.6	39.5
121	4.12.2024 22.20.56	61.4	54.6	-8.5	39.5
122	4.12.2024 22.21.56	61.5	54.7	-8.4	39.8
123	4.12.2024 22.22.56	61.5	54.7	-8.2	39.5
124	4.12.2024 22.23.56	61.5	54.7	-8.3	39.7
125	4.12.2024 22.24.56	61.5	54.6	-8.1	39.4
126	4.12.2024 22.25.56	61.6	54.7	-8.4	39.7
127	4.12.2024 22.26.56	61.6	54.7	-8.4	39.7
128	4.12.2024 22.27.56	61.6	54.8	-8.3	39.8
129	4.12.2024 22.28.56	61.5	54.7	-8.4	39.5
130	4.12.2024 22.29.56	61.5	54.7	-8.4	39.8
131	4.12.2024 22.30.56	61.4	54.7	-8.3	39.8
132	4.12.2024 22.31.56	61.4	54.8	-8.4	39.8
133	4.12.2024 22.32.56	61.3	54.7	-8.4	39.9
134	4.12.2024 22.33.56	61.2	54.7	-8.3	39.7
135	4.12.2024 22.34.56	61.1	54.8	-8.4	39.6
136	4.12.2024 22.35.56	61.0	54.9	-8.4	39.6
137	4.12.2024 22.36.56	60.9	54.8	-8.5	39.6
138	4.12.2024 22.37.56	60.7	54.8	-8.5	39.6
139	4.12.2024 22.38.56	60.6	54.8	-8.2	39.6
140	4.12.2024 22.39.56	60.5	54.8	-8.2	39.6
141	4.12.2024 22.40.56	60.3	54.8	-8.2	39.9
142	4.12.2024 22.41.56	60.2	54.8	-8.2	39.8
143	4.12.2024 22.42.56	59.9	54.8	-8.3	40.0
144	4.12.2024 22.43.56	59.8	54.9	-8.4	39.9

ID	Date/time	BT25 MLP:ltä [°C]	BT3 paluu varaajalta MLP:hen [°C]	T ulkolämpötila [°C]	Patteriverkko menovesi [°C]
145	4.12.2024 22.44.56	59.7	54.9	-8.3	39.6
146	4.12.2024 22.45.56	59.5	54.9	-8.3	39.7
147	4.12.2024 22.46.56	59.3	54.9	-8.2	39.7
148	4.12.2024 22.47.56	59.2	54.8	-8.3	39.8
149	4.12.2024 22.48.56	59.0	54.8	-8.3	39.8
150	4.12.2024 22.49.56	58.9	54.8	-8.2	39.8
151	4.12.2024 22.50.56	58.7	54.8	-8.4	39.9
152	4.12.2024 22.51.56	58.6	54.8	-8.4	39.7
153	4.12.2024 22.52.56	58.5	54.8	-8.2	39.8
154	4.12.2024 22.53.56	58.4	54.8	-8.3	39.6
155	4.12.2024 22.54.56	58.3	54.8	-8.4	39.7
156	4.12.2024 22.55.56	58.3	54.9	-8.3	39.9
157	4.12.2024 22.56.56	58.2	54.9	-8.4	40.1
158	4.12.2024 22.57.56	58.0	54.8	-8.4	39.9
159	4.12.2024 22.58.56	58.0	54.8	-8.6	40.1
160	4.12.2024 22.59.56	57.9	54.8	-8.4	40.2
161	4.12.2024 23.00.56	57.8	54.8	-8.4	40.0
162	4.12.2024 23.01.56	57.8	54.8	-8.5	40.5
163	4.12.2024 23.02.56	57.7	54.8	-8.5	40.2
164	4.12.2024 23.03.56	57.7	54.7	-8.5	40.2
165	4.12.2024 23.04.56	57.4	54.7	-8.5	40.2
166	4.12.2024 23.05.56	57.5	54.7	-8.2	40.4
167	4.12.2024 23.06.56	57.5	54.8	-8.4	40.3
168	4.12.2024 23.07.56	57.5	54.8	-8.4	40.4
169	4.12.2024 23.08.56	57.6	54.8	-8.4	40.4
170	4.12.2024 23.09.56	57.6	54.7	-8.3	40.3
171	4.12.2024 23.10.56	57.6	54.7	-8.5	40.5
172	4.12.2024 23.11.56	57.6	54.8	-8.3	40.3
173	4.12.2024 23.12.56	57.6	54.8	-8.3	40.6
174	4.12.2024 23.13.56	57.6	54.8	-8.2	40.7
175	4.12.2024 23.14.56	57.5	54.9	-8.2	40.3
176	4.12.2024 23.15.56	57.5	54.9	-8.2	40.4
177	4.12.2024 23.16.56	57.5	55.0	-8.3	40.3
178	4.12.2024 23.17.56	57.5	55.0	-8.2	40.6
179	4.12.2024 23.18.56	57.5	55.0	-8.2	40.3
180	4.12.2024 23.19.56	57.5	55.2	-8.3	40.6
181	4.12.2024 23.20.56	57.5	55.3	-8.3	40.5
182	4.12.2024 23.21.56	57.6	55.8	-8.3	40.5
183	4.12.2024 23.22.56	57.7	55.9	-8.2	40.4
184	4.12.2024 23.23.56	57.7	56.1	-8.3	40.5
185	4.12.2024 23.24.56	57.9	56.2	-8.3	40.7
186	4.12.2024 23.25.56	58.0	56.6	-8.2	40.7
187	4.12.2024 23.26.56	58.0	56.5	-8.3	40.3
188	4.12.2024 23.27.56	57.8	56.1	-8.2	40.4

ID	Date/time	BT25 MLP:ltä [°C]	BT3 paluu varaajalta MLP:hen [°C]	T ulkolämpötila [°C]	Patteriverkko menovesi [°C]
189	4.12.2024 23.28.56	57.9	55.5	-8.2	40.5
190	4.12.2024 23.29.56	57.7	56.0	-8.3	40.3
191	4.12.2024 23.30.56	57.6	56.2	-8.2	40.3
192	4.12.2024 23.31.56	57.7	56.3	-8.3	40.3
193	4.12.2024 23.32.56	57.6	56.4	-8.2	40.7
194	4.12.2024 23.33.56	57.6	56.6	-8.2	40.4
195	4.12.2024 23.34.56	57.6	56.6	-8.2	40.5
196	4.12.2024 23.35.56	57.6	56.7	-8.3	40.4
197	4.12.2024 23.36.56	57.6	56.7	-8.3	40.6
198	4.12.2024 23.37.56	57.6	56.6	-8.2	40.5
199	4.12.2024 23.38.56	57.7	56.6	-8.3	40.6
200	4.12.2024 23.39.56	57.7	56.4	-8.3	40.6
201	4.12.2024 23.40.56	57.7	56.3	-8.3	40.4
202	4.12.2024 23.41.56	57.7	56.3	-8.1	40.4
203	4.12.2024 23.42.56	57.7	56.3	-8.1	40.3
204	4.12.2024 23.43.56	57.7	56.3	-8.3	40.4
205	4.12.2024 23.44.56	57.7	56.4	-8.2	40.7
206	4.12.2024 23.45.56	58.1	56.4	-8.2	40.8
207	4.12.2024 23.46.56	58.5	56.3	-8.2	40.8
208	4.12.2024 23.47.56	58.4	56.1	-8.3	40.4
209	4.12.2024 23.48.56	58.2	56.1	-8.3	40.6
210	4.12.2024 23.49.56	58.0	56.1	-8.2	----
211	4.12.2024 23.50.56	57.8	56.3	-8.1	----
212	4.12.2024 23.51.56	57.7	56.3	-8.1	----
213	4.12.2024 23.52.56	57.7	56.1	-8.1	----
214	4.12.2024 23.53.56	57.7	55.9	-8.3	----
215	4.12.2024 23.54.56	57.6	56.0	-8.2	----
216	4.12.2024 23.55.56	57.6	56.2	-8.1	----
217	4.12.2024 23.56.56	57.6	56.1	-8.3	----
218	4.12.2024 23.57.56	57.6	56.4	-8.0	----
219	4.12.2024 23.58.56	57.6	56.3	-8.2	----
220	4.12.2024 23.59.56	57.6	56.1	-8.0	----
221	5.12.2024 0.00.56	57.6	56.1	-8.2	----
222	5.12.2024 0.01.56	57.5	56.2	-8.2	----
223	5.12.2024 0.02.56	57.6	56.3	-8.2	----
224	5.12.2024 0.03.56	57.6	56.2	-8.2	----
225	5.12.2024 0.04.56	57.5	56.3	-8.2	----
226	5.12.2024 0.05.56	57.6	56.1	-8.0	----
227	5.12.2024 0.06.56	57.7	56.2	-8.2	----
228	5.12.2024 0.07.56	58.3	56.0	-8.3	----
229	5.12.2024 0.08.56	58.3	56.0	-8.3	----
230	5.12.2024 0.09.56	58.1	56.0	-8.3	----
231	5.12.2024 0.10.56	57.9	56.1	-8.2	----
232	5.12.2024 0.11.56	57.6	55.9	-8.3	----

ID	Date/time	BT25 MLP:ltä [°C]	BT3 paluu varaajalta MLP:hen [°C]	T ulkolämpötila [°C]	Patteriverkko menovesi [°C]
233	5.12.2024 0.12.56	57.6	55.9	-8.2	----
234	5.12.2024 0.13.56	57.5	55.9	-8.2	----
235	5.12.2024 0.14.56	57.5	55.9	-8.2	----
236	5.12.2024 0.15.56	57.5	55.9	-8.3	----
237	5.12.2024 0.16.56	57.4	56.1	-8.2	----
238	5.12.2024 0.17.56	57.4	55.9	-8.2	----
239	5.12.2024 0.18.56	57.4	55.9	-8.0	----
240	5.12.2024 0.19.56	57.4	56.1	-8.0	----
241	5.12.2024 0.20.56	57.4	56.1	-8.1	----
242	5.12.2024 0.21.56	57.4	55.8	-8.2	----
243	5.12.2024 0.22.56	57.4	55.9	-8.0	----
244	5.12.2024 0.23.56	57.4	56.1	-8.0	----
245	5.12.2024 0.24.56	57.4	56.2	-8.1	----
246	5.12.2024 0.25.56	57.4	56.0	-8.2	----
247	5.12.2024 0.26.56	57.4	56.0	-8.1	----
248	5.12.2024 0.27.56	57.4	56.2	-8.1	----
249	5.12.2024 0.28.56	58.0	56.2	-8.1	----
250	5.12.2024 0.29.56	58.2	56.1	-8.2	----
251	5.12.2024 0.30.56	57.1	55.8	-8.2	----
252	5.12.2024 0.31.56	55.3	55.2	-8.3	----
253	5.12.2024 0.32.56	54.6	55.0	-8.2	----
254	5.12.2024 0.33.56	54.3	54.8	-8.2	----
255	5.12.2024 0.34.56	54.2	54.8	-8.1	----
256	5.12.2024 0.35.56	54.2	55.1	-8.0	----
257	5.12.2024 0.36.56	54.2	55.8	-8.1	----
258	5.12.2024 0.37.56	54.9	56.3	-8.1	----
259	5.12.2024 0.38.56	55.3	56.1	-8.0	----
260	5.12.2024 0.39.56	55.3	56.4	-8.0	----
261	5.12.2024 0.40.56	55.4	56.6	-7.9	----
262	5.12.2024 0.41.56	55.6	56.6	-8.1	----
263	5.12.2024 0.42.56	55.6	56.6	-8.0	----
264	5.12.2024 0.43.56	55.5	56.6	-8.1	----
265	5.12.2024 0.44.56	55.5	56.6	-8.2	----
266	5.12.2024 0.45.56	55.7	56.5	-8.2	----
267	5.12.2024 0.46.56	55.7	56.5	-8.1	----
268	5.12.2024 0.47.56	55.5	56.5	-8.2	----
269	5.12.2024 0.48.56	55.6	55.8	-8.3	----
270	5.12.2024 0.49.56	55.3	55.0	-8.2	----
271	5.12.2024 0.50.56	54.7	55.0	-8.2	----
272	5.12.2024 0.51.56	54.3	54.6	-8.2	----
273	5.12.2024 0.52.56	54.1	54.5	-8.2	----
274	5.12.2024 0.53.56	54.3	54.2	-8.1	----
275	5.12.2024 0.54.56	54.0	54.9	-8.1	----
276	5.12.2024 0.55.56	53.9	54.5	-8.1	----

ID	Date/time	BT25 MLP:ltä [°C]	BT3 paluu varaajalta MLP:hen [°C]	T ulkolämpötila [°C]	Patteriverkko menovesi [°C]
277	5.12.2024 0.56.56	53.9	54.3	-8.1	----
278	5.12.2024 0.57.56	54.0	55.0	-8.2	----
279	5.12.2024 0.58.56	54.9	54.9	-8.2	----
280	5.12.2024 0.59.56	56.3	54.9	-8.1	----
281	5.12.2024 1.00.56	56.7	54.6	-8.3	----
282	5.12.2024 1.01.56	56.7	54.9	-8.2	----
283	5.12.2024 1.02.56	56.7	54.8	-8.3	----
284	5.12.2024 1.03.56	56.6	54.9	-8.2	----
285	5.12.2024 1.04.56	56.6	54.9	-8.3	----
286	5.12.2024 1.05.56	56.5	54.6	-8.0	----
287	5.12.2024 1.06.56	56.4	54.4	-8.1	----
288	5.12.2024 1.07.56	56.4	54.6	-8.1	----
289	5.12.2024 1.08.56	56.3	54.8	-8.2	----
290	5.12.2024 1.09.56	56.3	54.8	-8.3	----
291	5.12.2024 1.10.56	56.3	54.7	-8.4	----
292	5.12.2024 1.11.56	56.3	54.7	-8.3	----
293	5.12.2024 1.12.56	56.3	54.5	-8.3	----
294	5.12.2024 1.13.56	56.2	54.2	-8.4	----
295	5.12.2024 1.14.56	56.2	54.0	-8.4	----
296	5.12.2024 1.15.56	56.2	54.5	-8.4	----
297	5.12.2024 1.16.56	56.2	54.5	-8.4	----
298	5.12.2024 1.17.56	56.2	54.2	-8.3	----
299	5.12.2024 1.18.56	56.9	54.2	-8.4	----
300	5.12.2024 1.19.56	56.5	54.4	-8.2	----
301	5.12.2024 1.20.56	56.3	54.6	-8.3	----
302	5.12.2024 1.21.56	56.2	54.5	-8.4	----
303	5.12.2024 1.22.56	56.2	54.5	-8.3	----
304	5.12.2024 1.23.56	56.2	54.6	-8.3	----
305	5.12.2024 1.24.56	56.1	54.7	-8.2	----
306	5.12.2024 1.25.56	56.1	54.5	-8.2	----
307	5.12.2024 1.26.56	56.1	54.3	-8.2	----
308	5.12.2024 1.27.56	56.1	54.5	-8.3	----
309	5.12.2024 1.28.56	56.0	54.6	-8.3	----
310	5.12.2024 1.29.56	56.0	54.3	-8.3	----
311	5.12.2024 1.30.56	56.0	54.1	-8.3	----
312	5.12.2024 1.31.56	56.0	54.4	-8.2	----
313	5.12.2024 1.32.56	56.0	54.5	-8.3	----
314	5.12.2024 1.33.56	56.0	54.5	-8.3	----
315	5.12.2024 1.34.56	56.0	54.7	-8.3	----
316	5.12.2024 1.35.56	56.0	54.6	-8.3	----
317	5.12.2024 1.36.56	56.1	54.7	-8.3	----
318	5.12.2024 1.37.56	56.3	54.7	-8.2	----
319	5.12.2024 1.38.56	56.4	54.6	-8.3	----
320	5.12.2024 1.39.56	56.8	54.5	-8.2	----

ID	Date/time	BT25 MLP:ltä [°C]	BT3 paluu varaajalta MLP:hen [°C]	T ulkolämpötila [°C]	Patteriverkko menovesi [°C]
321	5.12.2024 1.40.56	57.0	54.4	-8.3	----
322	5.12.2024 1.41.56	57.1	54.3	-8.2	----
323	5.12.2024 1.42.56	57.2	54.3	-8.1	----
324	5.12.2024 1.43.56	57.4	54.3	-8.1	----
325	5.12.2024 1.44.56	57.5	54.4	-8.2	----
326	5.12.2024 1.45.56	57.6	54.4	-8.2	----
327	5.12.2024 1.46.56	57.7	54.3	-8.1	----
328	5.12.2024 1.47.56	57.8	54.5	-8.1	----
329	5.12.2024 1.48.56	57.8	54.4	-8.1	----
330	5.12.2024 1.49.56	57.8	54.3	-8.2	----
331	5.12.2024 1.50.56	57.9	54.3	-8.2	----
332	5.12.2024 1.51.56	57.9	54.3	-8.3	----
333	5.12.2024 1.52.56	57.9	54.4	-8.3	----
334	5.12.2024 1.53.56	57.9	54.4	-8.2	----
335	5.12.2024 1.54.56	57.9	54.4	-8.2	----
336	5.12.2024 1.55.56	57.9	54.4	-8.2	----
337	5.12.2024 1.56.56	57.9	54.4	-8.2	----
338	5.12.2024 1.57.56	57.9	54.3	-8.3	----
339	5.12.2024 1.58.56	57.9	54.3	-8.2	----
340	5.12.2024 1.59.56	57.9	54.3	-8.1	----
341	5.12.2024 2.00.56	57.8	54.3	-8.1	----
342	5.12.2024 2.01.56	57.8	54.4	-8.1	----
343	5.12.2024 2.02.56	57.8	54.4	-8.0	----
344	5.12.2024 2.03.56	57.8	54.4	-8.2	----
345	5.12.2024 2.04.56	57.8	54.4	-8.3	----
346	5.12.2024 2.05.56	57.8	54.3	-8.1	----
347	5.12.2024 2.06.56	57.8	54.3	-8.1	----
348	5.12.2024 2.07.56	57.8	54.3	-8.1	----
349	5.12.2024 2.08.56	57.8	54.3	-8.2	----
350	5.12.2024 2.09.56	57.7	54.3	-8.0	----
351	5.12.2024 2.10.56	57.8	54.4	-8.1	----
352	5.12.2024 2.11.56	57.7	54.4	-8.0	----
353	5.12.2024 2.12.56	57.7	54.4	-8.3	----
354	5.12.2024 2.13.56	57.7	54.4	-8.3	----
355	5.12.2024 2.14.56	57.6	54.5	-8.2	----
356	5.12.2024 2.15.56	57.6	54.4	-8.2	----
357	5.12.2024 2.16.56	57.5	54.4	-8.2	----
358	5.12.2024 2.17.56	57.5	54.4	-8.2	----
359	5.12.2024 2.18.56	57.4	54.4	-8.3	----
360	5.12.2024 2.19.56	57.4	54.4	-8.2	----
361	5.12.2024 2.20.56	57.3	54.5	-8.2	----
362	5.12.2024 2.21.56	57.3	54.5	-8.2	----
363	5.12.2024 2.22.56	57.3	54.5	-8.1	----
364	5.12.2024 2.23.56	57.3	54.5	-8.1	----

ID	Date/time	BT25 MLP:ltä [°C]	BT3 paluu varaajalta MLP:hen [°C]	T ulkolämpötila [°C]	Patteriverkko menovesi [°C]
365	5.12.2024 2.24.56	57.2	54.6	-8.1	----
366	5.12.2024 2.25.56	57.2	54.5	-8.1	----
367	5.12.2024 2.26.56	57.2	54.5	-8.2	----
368	5.12.2024 2.27.56	57.2	54.5	-8.1	----
369	5.12.2024 2.28.56	57.2	54.5	-8.2	----
370	5.12.2024 2.29.56	57.2	54.5	-8.0	----
371	5.12.2024 2.30.56	57.1	54.6	-8.0	----
372	5.12.2024 2.31.56	57.1	54.5	-8.1	----
373	5.12.2024 2.32.56	57.1	54.6	-8.1	----
374	5.12.2024 2.33.56	57.0	54.5	-8.2	----
375	5.12.2024 2.34.56	57.1	54.5	-8.0	----
376	5.12.2024 2.35.56	57.1	54.5	-8.0	----
377	5.12.2024 2.36.56	57.0	54.4	-8.0	----
378	5.12.2024 2.37.56	57.1	54.4	-8.0	----
379	5.12.2024 2.38.56	57.1	54.5	-8.1	----
380	5.12.2024 2.39.56	57.1	54.5	-8.1	----
381	5.12.2024 2.40.56	57.1	54.4	-8.1	----
382	5.12.2024 2.41.56	57.1	54.4	-8.0	----
383	5.12.2024 2.42.56	57.1	54.5	-8.1	----
384	5.12.2024 2.43.56	57.1	54.5	-8.0	----
385	5.12.2024 2.44.56	57.1	54.5	-8.0	----
386	5.12.2024 2.45.56	57.1	54.5	-8.0	----
387	5.12.2024 2.46.56	57.2	54.6	-8.0	----
388	5.12.2024 2.47.56	57.1	54.6	-8.0	----
389	5.12.2024 2.48.56	57.2	54.6	-8.0	----
390	5.12.2024 2.49.56	57.2	54.7	-7.8	----
391	5.12.2024 2.50.56	57.2	54.8	-8.1	----
392	5.12.2024 2.51.56	57.3	54.8	-8.0	----
393	5.12.2024 2.52.56	57.3	54.8	-8.1	----
394	5.12.2024 2.53.56	57.3	54.9	-8.1	----
395	5.12.2024 2.54.56	57.3	54.8	-8.1	----
396	5.12.2024 2.55.56	57.3	54.8	-8.1	----
397	5.12.2024 2.56.56	57.4	54.9	-8.1	----
398	5.12.2024 2.57.56	57.4	54.9	-8.1	----
399	5.12.2024 2.58.56	57.4	55.0	-8.1	----
400	5.12.2024 2.59.56	57.4	55.0	-8.1	----
401	5.12.2024 3.00.56	57.4	54.9	-8.1	----
402	5.12.2024 3.01.56	57.4	55.0	-8.1	----
403	5.12.2024 3.02.56	57.3	54.9	-8.0	----
404	5.12.2024 3.03.56	57.3	55.0	-8.0	----
405	5.12.2024 3.04.56	57.3	55.1	-8.0	----
406	5.12.2024 3.05.56	57.2	55.0	-7.9	----
407	5.12.2024 3.06.56	57.2	55.0	-7.9	----
408	5.12.2024 3.07.56	57.2	55.0	-7.8	----

ID	Date/time	BT25 MLP:ltä [°C]	BT3 paluu varaajalta MLP:hen [°C]	T ulkolämpötila [°C]	Patteriverkko menovesi [°C]
409	5.12.2024 3.08.56	57.2	55.1	-8.0	----
410	5.12.2024 3.09.56	57.1	55.1	-7.9	----
411	5.12.2024 3.10.56	57.2	55.0	-7.8	----
412	5.12.2024 3.11.56	57.1	55.0	-7.7	----
413	5.12.2024 3.12.56	57.1	55.0	-7.9	----
414	5.12.2024 3.13.56	57.1	55.0	-7.8	----
415	5.12.2024 3.14.56	57.0	55.0	-7.9	----
416	5.12.2024 3.15.56	57.1	55.1	-7.9	----
417	5.12.2024 3.16.56	57.1	55.1	-7.9	----
418	5.12.2024 3.17.56	57.1	55.1	-7.9	----
419	5.12.2024 3.18.56	57.2	55.0	-7.9	----
420	5.12.2024 3.19.56	57.2	55.1	-7.9	----
421	5.12.2024 3.20.56	57.1	55.1	-7.5	----
422	5.12.2024 3.21.56	57.2	55.1	-7.8	----
423	5.12.2024 3.22.56	57.1	55.1	-7.9	----
424	5.12.2024 3.23.56	57.1	55.1	-7.8	----
425	5.12.2024 3.24.56	57.2	55.1	-7.5	----
426	5.12.2024 3.25.56	57.2	55.2	-7.6	----
427	5.12.2024 3.26.56	57.2	55.2	-7.4	----
428	5.12.2024 3.27.56	57.2	55.2	-7.7	----
429	5.12.2024 3.28.56	57.2	55.2	-7.8	----
430	5.12.2024 3.29.56	57.2	55.2	-7.6	----
431	5.12.2024 3.30.56	57.2	55.2	-7.7	----
432	5.12.2024 3.31.56	57.2	55.1	-7.7	----
433	5.12.2024 3.32.56	57.2	55.1	-7.8	----
434	5.12.2024 3.33.56	57.2	55.1	-7.8	----
435	5.12.2024 3.34.56	57.3	55.0	-7.8	----
436	5.12.2024 3.35.56	57.3	55.1	-7.9	----
437	5.12.2024 3.36.56	57.3	55.1	-7.9	----
438	5.12.2024 3.37.56	57.3	55.1	-7.9	----
439	5.12.2024 3.38.56	57.2	55.1	-8.0	----
440	5.12.2024 3.39.56	57.3	55.1	-7.9	40.4
441	5.12.2024 3.40.56	57.3	55.1	-7.9	40.4
442	5.12.2024 3.41.56	57.3	55.1	-8.2	40.3
443	5.12.2024 3.42.56	57.3	55.1	-8.0	40.4
444	5.12.2024 3.43.56	57.3	55.0	-8.0	40.2
445	5.12.2024 3.44.56	57.2	55.0	-8.1	40.3
446	5.12.2024 3.45.56	57.3	54.9	-8.0	40.2
447	5.12.2024 3.46.56	57.3	54.9	-8.1	40.2
448	5.12.2024 3.47.56	57.3	54.9	-8.0	40.3
449	5.12.2024 3.48.56	57.3	54.9	-8.1	40.3
450	5.12.2024 3.49.56	57.3	54.9	-8.0	40.3
451	5.12.2024 3.50.56	57.2	55.0	-8.1	40.3
452	5.12.2024 3.51.56	57.3	55.0	-8.2	40.3

ID	Date/time	BT25 MLP:ltä [°C]	BT3 paluu varaajalta MLP:hen [°C]	T ulkolämpötila [°C]	Patteriverkko menovesi [°C]
453	5.12.2024 3.52.56	57.2	55.0	-8.1	40.1
454	5.12.2024 3.53.56	57.2	54.9	-8.1	40.3
455	5.12.2024 3.54.56	57.2	55.0	-8.1	40.1
456	5.12.2024 3.55.56	57.2	55.1	-8.2	40.2
457	5.12.2024 3.56.56	57.2	55.1	-8.1	40.3
458	5.12.2024 3.57.56	57.2	55.0	-8.1	40.3
459	5.12.2024 3.58.56	57.2	55.0	-8.0	40.1
460	5.12.2024 3.59.56	57.2	55.1	-8.2	40.2
461	5.12.2024 4.00.56	57.2	55.1	-8.1	40.3
462	5.12.2024 4.01.56	57.2	55.1	-8.2	40.2
463	5.12.2024 4.02.56	57.2	55.1	-8.2	40.5
464	5.12.2024 4.03.56	57.2	55.0	-8.2	40.2
465	5.12.2024 4.04.56	57.2	55.0	-8.2	40.0
466	5.12.2024 4.05.56	57.2	55.1	-8.2	40.4
467	5.12.2024 4.06.56	57.2	55.1	-8.2	40.5
468	5.12.2024 4.07.56	57.2	55.2	-8.0	40.3
469	5.12.2024 4.08.56	57.2	55.1	-8.0	40.2
470	5.12.2024 4.09.56	57.2	55.1	-8.1	40.3
471	5.12.2024 4.10.56	57.2	55.2	-8.0	40.6
472	5.12.2024 4.11.56	57.2	55.2	-8.0	40.3
473	5.12.2024 4.12.56	57.2	55.0	-7.9	40.6
474	5.12.2024 4.13.56	57.2	55.0	-8.0	----
475	5.12.2024 4.14.56	57.2	55.0	-7.9	----
476	5.12.2024 4.15.56	57.2	54.9	-8.0	----
477	5.12.2024 4.16.56	57.2	55.0	-7.8	----
478	5.12.2024 4.17.56	57.2	55.0	-7.9	----
479	5.12.2024 4.18.56	57.2	55.0	-7.9	----
480	5.12.2024 4.19.56	57.2	55.0	-7.9	40.4
481	5.12.2024 4.20.56	57.2	55.1	-7.8	40.6
482	5.12.2024 4.21.56	57.2	55.0	-7.9	40.9
483	5.12.2024 4.22.56	57.2	55.1	-7.8	40.9
484	5.12.2024 4.23.56	57.2	55.1	-7.8	40.6
485	5.12.2024 4.24.56	57.2	55.1	-7.6	40.2
486	5.12.2024 4.25.56	57.2	55.1	-7.7	40.3
487	5.12.2024 4.26.56	57.1	55.1	-7.9	40.5
488	5.12.2024 4.27.56	57.2	55.0	-7.8	40.6
489	5.12.2024 4.28.56	57.1	54.9	-7.9	40.3
490	5.12.2024 4.29.56	57.2	55.0	-8.0	40.6
491	5.12.2024 4.30.56	57.1	55.0	-8.0	40.4
492	5.12.2024 4.31.56	57.2	55.0	-8.0	40.4
493	5.12.2024 4.32.56	57.2	55.0	-8.0	40.6
494	5.12.2024 4.33.56	57.2	55.1	-7.8	40.3
495	5.12.2024 4.34.56	57.2	55.0	-8.0	40.3
496	5.12.2024 4.35.56	57.2	55.0	-8.0	40.4

ID	Date/time	BT25 MLP:ltä [°C]	BT3 paluu varaajalta MLP:hen [°C]	T ulkolämpötila [°C]	Patteriverkko menovesi [°C]
497	5.12.2024 4.36.56	57.1	55.0	-8.1	40.3
498	5.12.2024 4.37.56	57.2	55.0	-7.9	40.4
499	5.12.2024 4.38.56	57.2	55.0	-7.8	40.4
500	5.12.2024 4.39.56	57.1	55.0	-7.9	40.4
501	5.12.2024 4.40.56	57.2	55.0	-8.0	40.6
502	5.12.2024 4.41.56	57.2	55.0	-7.9	40.6
503	5.12.2024 4.42.56	57.2	55.0	-7.9	40.4
504	5.12.2024 4.43.56	57.2	55.0	-7.9	40.5
505	5.12.2024 4.44.56	57.2	55.0	-7.8	40.6
506	5.12.2024 4.45.56	57.2	55.0	-7.9	40.5
507	5.12.2024 4.46.56	57.2	55.0	-8.0	40.4
508	5.12.2024 4.47.56	57.1	55.0	-8.1	40.5
509	5.12.2024 4.48.56	57.2	55.0	-8.0	40.6
510	5.12.2024 4.49.56	57.1	55.0	-8.0	40.3
511	5.12.2024 4.50.56	57.1	55.0	-8.0	40.3
512	5.12.2024 4.51.56	57.2	55.1	-8.0	40.3
513	5.12.2024 4.52.56	57.1	55.0	-7.9	40.6
514	5.12.2024 4.53.56	57.2	55.1	-7.8	40.6
515	5.12.2024 4.54.56	57.2	55.0	-8.0	40.3
516	5.12.2024 4.55.56	57.1	55.0	-7.9	40.4
517	5.12.2024 4.56.56	57.2	55.0	-7.9	40.6
518	5.12.2024 4.57.56	57.2	54.9	-7.8	40.4
519	5.12.2024 4.58.56	57.2	54.8	-7.8	40.6
520	5.12.2024 4.59.56	57.2	54.9	-7.8	40.5
521	5.12.2024 5.00.56	57.2	54.9	-7.9	40.5
522	5.12.2024 5.01.56	57.2	54.9	-8.0	40.6
523	5.12.2024 5.02.56	57.2	55.0	-7.9	40.5
524	5.12.2024 5.03.56	57.1	55.0	-7.9	40.5
525	5.12.2024 5.04.56	57.2	54.9	-8.0	40.3
526	5.12.2024 5.05.56	57.2	54.9	-7.9	40.4
527	5.12.2024 5.06.56	57.1	55.0	-7.9	40.4
528	5.12.2024 5.07.56	57.2	55.1	-7.9	40.4
529	5.12.2024 5.08.56	57.2	55.0	-7.9	40.6
530	5.12.2024 5.09.56	57.1	55.0	-7.9	40.6
531	5.12.2024 5.10.56	57.2	54.9	-7.9	40.3
532	5.12.2024 5.11.56	57.1	54.9	-7.9	40.5
533	5.12.2024 5.12.56	57.1	54.9	-7.9	40.6
534	5.12.2024 5.13.56	57.1	55.0	-8.0	40.5
535	5.12.2024 5.14.56	57.1	55.0	-7.9	40.6
536	5.12.2024 5.15.56	57.1	55.0	-8.1	40.6
537	5.12.2024 5.16.56	57.1	55.0	-8.1	40.3
538	5.12.2024 5.17.56	57.1	55.0	-8.0	40.5
539	5.12.2024 5.18.56	57.1	55.0	-7.9	40.3
540	5.12.2024 5.19.56	57.1	54.9	-7.8	40.4

ID	Date/time	BT25 MLP:ltä [°C]	BT3 paluu varaajalta MLP:hen [°C]	T ulkolämpötila [°C]	Patteriverkko menovesi [°C]
541	5.12.2024 5.20.56	57.1	55.0	-7.8	40.3
542	5.12.2024 5.21.56	57.2	55.0	-8.0	40.4
543	5.12.2024 5.22.56	57.2	55.0	-7.9	40.5
544	5.12.2024 5.23.56	57.1	55.0	-7.9	40.4
545	5.12.2024 5.24.56	57.2	55.0	-8.0	40.5
546	5.12.2024 5.25.56	57.1	55.0	-8.0	40.5
547	5.12.2024 5.26.56	57.1	55.1	-8.1	40.7
548	5.12.2024 5.27.56	57.1	55.1	-8.0	40.5
549	5.12.2024 5.28.56	57.1	54.9	-8.0	40.3
550	5.12.2024 5.29.56	57.1	54.9	-7.9	40.6
551	5.12.2024 5.30.56	57.1	54.9	-8.0	40.6
552	5.12.2024 5.31.56	57.1	54.8	-8.0	40.5
553	5.12.2024 5.32.56	57.1	54.8	-8.2	40.2
554	5.12.2024 5.33.56	57.1	54.9	-8.1	40.6
555	5.12.2024 5.34.56	57.1	54.9	-8.1	40.7
556	5.12.2024 5.35.56	57.1	54.9	-8.2	40.4
557	5.12.2024 5.36.56	57.1	54.9	-8.1	40.4
558	5.12.2024 5.37.56	57.1	55.0	-7.9	40.7
559	5.12.2024 5.38.56	57.1	55.0	-7.9	40.2
560	5.12.2024 5.39.56	57.1	54.9	-7.8	40.7
561	5.12.2024 5.40.56	57.1	54.9	-7.7	40.8
562	5.12.2024 5.41.56	57.1	55.0	-7.8	40.5
563	5.12.2024 5.42.56	57.1	55.0	-7.8	40.7
564	5.12.2024 5.43.56	57.2	55.0	-7.8	40.7
565	5.12.2024 5.44.56	57.1	55.0	-7.8	40.4
566	5.12.2024 5.45.56	57.1	55.0	-8.0	40.3
567	5.12.2024 5.46.56	57.2	54.9	-7.9	40.8
568	5.12.2024 5.47.56	57.1	54.9	-7.9	40.9
569	5.12.2024 5.48.56	57.1	54.9	-8.0	40.7
570	5.12.2024 5.49.56	57.1	54.9	-7.9	40.8
571	5.12.2024 5.50.56	57.1	55.0	-7.9	40.4
572	5.12.2024 5.51.56	57.1	55.0	-8.0	40.7
573	5.12.2024 5.52.56	57.1	55.0	-8.0	40.6
574	5.12.2024 5.53.56	57.1	55.0	-7.9	40.5
575	5.12.2024 5.54.56	57.1	55.0	-7.8	40.7
576	5.12.2024 5.55.56	57.1	55.0	-7.9	40.4
577	5.12.2024 5.56.56	57.1	54.9	-8.0	40.8
578	5.12.2024 5.57.56	57.1	55.0	-8.1	40.8
579	5.12.2024 5.58.56	57.1	54.9	-8.1	40.7
580	5.12.2024 5.59.56	57.1	55.0	-8.0	40.7
581	5.12.2024 6.00.56	57.1	55.0	-8.1	40.4
582	5.12.2024 6.01.56	57.1	54.9	-8.1	40.5
583	5.12.2024 6.02.56	57.1	55.0	-8.0	40.8
584	5.12.2024 6.03.56	57.1	55.0	-8.0	40.9

ID	Date/time	BT25 MLP:ltä [°C]	BT3 paluu varaajalta MLP:hen [°C]	T ulkolämpötila [°C]	Patteriverkko menovesi [°C]
585	5.12.2024 6.04.56	57.1	55.0	-8.1	40.5
586	5.12.2024 6.05.56	57.1	55.0	-8.0	40.9
587	5.12.2024 6.06.56	57.1	54.9	-8.1	40.7
588	5.12.2024 6.07.56	57.1	54.8	-8.2	40.3
589	5.12.2024 6.08.56	57.1	54.9	-8.2	40.8
590	5.12.2024 6.09.56	57.1	54.9	-8.3	40.3
591	5.12.2024 6.10.56	57.1	54.9	-8.3	40.5
592	5.12.2024 6.11.56	57.1	54.9	-8.2	40.4
593	5.12.2024 6.12.56	57.1	54.9	-8.3	40.3
594	5.12.2024 6.13.56	57.1	55.0	-8.2	40.5
595	5.12.2024 6.14.56	57.1	55.0	-8.3	40.4
596	5.12.2024 6.15.56	57.1	55.0	-8.2	40.6
597	5.12.2024 6.16.56	57.1	55.0	-8.2	40.5
598	5.12.2024 6.17.56	57.1	54.9	-8.2	40.7
599	5.12.2024 6.18.56	57.1	54.9	-8.2	40.4
600	5.12.2024 6.19.56	57.1	55.0	-8.3	40.2
601	5.12.2024 6.20.56	57.1	55.0	-8.1	40.4
602	5.12.2024 6.21.56	57.1	55.0	-8.0	40.4
603	5.12.2024 6.22.56	57.1	55.0	-8.1	40.4
604	5.12.2024 6.23.56	57.1	54.9	-8.1	40.9
605	5.12.2024 6.24.56	57.1	54.9	-8.1	40.6
606	5.12.2024 6.25.56	57.1	54.9	-8.1	40.9
607	5.12.2024 6.26.56	57.1	54.9	-8.1	41.3
608	5.12.2024 6.27.56	57.1	55.0	-8.0	40.3
609	5.12.2024 6.28.56	57.1	54.9	-7.9	39.7
610	5.12.2024 6.29.56	57.1	54.8	-8.0	39.8
611	5.12.2024 6.30.56	57.1	54.9	-7.9	40.2
612	5.12.2024 6.31.56	57.1	54.9	-8.1	40.5
613	5.12.2024 6.32.56	57.1	54.9	-7.9	41.1
614	5.12.2024 6.33.56	57.1	55.0	-8.0	41.4
615	5.12.2024 6.34.56	57.1	54.9	-8.0	39.9
616	5.12.2024 6.35.56	57.1	55.0	-8.0	43.0
617	5.12.2024 6.36.56	57.1	55.0	-8.0	----
618	5.12.2024 6.37.56	57.1	54.9	-7.9	----
619	5.12.2024 6.38.56	57.1	54.9	-8.1	----
620	5.12.2024 6.39.56	57.1	54.9	-8.2	----
621	5.12.2024 6.40.56	57.1	54.9	-8.0	----
622	5.12.2024 6.41.56	57.1	54.9	-8.1	----
623	5.12.2024 6.42.56	57.1	54.4	-8.2	----
624	5.12.2024 6.43.56	57.1	54.0	-8.1	----
625	5.12.2024 6.44.56	57.0	54.2	-8.0	----
626	5.12.2024 6.45.56	56.9	54.5	-7.9	----
627	5.12.2024 6.46.56	56.9	54.5	-7.9	----
628	5.12.2024 6.47.56	56.9	54.4	-8.0	----

ID	Date/time	BT25 MLP:ltä [°C]	BT3 paluu varaajalta MLP:hen [°C]	T ulkolämpötila [°C]	Patteriverkko menovesi [°C]
629	5.12.2024 6.48.56	56.8	54.4	-8.0	----
630	5.12.2024 6.49.56	56.7	54.5	-8.0	----
631	5.12.2024 6.50.56	56.7	54.5	-7.9	----
632	5.12.2024 6.51.56	56.7	54.5	-8.0	----
633	5.12.2024 6.52.56	56.6	54.6	-8.0	40.5
634	5.12.2024 6.53.56	56.6	54.6	-8.0	40.8
635	5.12.2024 6.54.56	56.6	54.4	-8.0	39.5
636	5.12.2024 6.55.56	56.6	54.3	-8.1	40.5
637	5.12.2024 6.56.56	56.7	54.4	-8.2	40.6
638	5.12.2024 6.57.56	56.7	54.5	-8.1	39.1
639	5.12.2024 6.58.56	56.7	54.2	-8.1	40.3
640	5.12.2024 6.59.56	56.7	54.1	-8.0	40.8
641	5.12.2024 7.00.56	56.7	54.1	-8.1	41.0
642	5.12.2024 7.01.56	56.7	54.0	-8.0	42.2
643	5.12.2024 7.02.56	56.8	53.2	-7.8	40.2
644	5.12.2024 7.03.56	56.9	53.3	-8.0	40.3
645	5.12.2024 7.04.56	56.7	53.7	-8.0	40.3
646	5.12.2024 7.05.56	56.7	54.1	-8.0	40.4
647	5.12.2024 7.06.56	56.8	53.9	-8.1	40.4
648	5.12.2024 7.07.56	56.7	54.2	-8.1	40.5
649	5.12.2024 7.08.56	56.8	54.3	-8.1	40.5
650	5.12.2024 7.09.56	56.9	54.2	-8.1	40.6
651	5.12.2024 7.10.56	56.8	54.3	-8.1	40.7
652	5.12.2024 7.11.56	56.8	54.1	-8.1	40.8
653	5.12.2024 7.12.56	57.1	53.1	-8.2	40.9
654	5.12.2024 7.13.56	56.8	53.6	-8.3	40.9
655	5.12.2024 7.14.56	56.6	54.2	-8.2	41.0
656	5.12.2024 7.15.56	56.8	54.1	-8.3	41.0
657	5.12.2024 7.16.56	56.6	54.0	-8.4	41.0
658	5.12.2024 7.17.56	56.7	54.3	-8.3	41.0
659	5.12.2024 7.18.56	56.8	54.1	-8.2	41.0
660	5.12.2024 7.19.56	56.8	54.1	-8.2	41.1
661	5.12.2024 7.20.56	56.8	54.2	-8.2	41.1
662	5.12.2024 7.21.56	56.9	54.2	-8.3	41.1
663	5.12.2024 7.22.56	56.8	54.3	-8.2	41.2
664	5.12.2024 7.23.56	57.0	54.3	-8.2	41.2
665	5.12.2024 7.24.56	57.0	54.5	-8.2	41.3
666	5.12.2024 7.25.56	57.0	54.5	-8.1	41.3
667	5.12.2024 7.26.56	57.0	54.4	-8.2	41.3
668	5.12.2024 7.27.56	57.0	54.4	-8.2	41.2
669	5.12.2024 7.28.56	57.0	54.5	-8.3	41.2
670	5.12.2024 7.29.56	57.1	54.5	-8.3	41.3
671	5.12.2024 7.30.56	57.0	54.5	-8.3	41.3
672	5.12.2024 7.31.56	57.1	54.4	-8.4	41.3

ID	Date/time	BT25 MLP:ltä [°C]	BT3 paluu varaajalta MLP:hen [°C]	T ulkolämpötila [°C]	Patteriverkko menovesi [°C]
673	5.12.2024 7.32.56	57.1	54.4	-8.2	41.3
674	5.12.2024 7.33.56	57.1	54.4	-8.1	41.3
675	5.12.2024 7.34.56	57.1	54.4	-8.2	41.3
676	5.12.2024 7.35.56	57.1	54.3	-8.2	41.4
677	5.12.2024 7.36.56	57.1	54.4	-8.2	41.4
678	5.12.2024 7.37.56	57.1	54.5	-8.2	41.4
679	5.12.2024 7.38.56	57.1	54.4	-8.2	41.4
680	5.12.2024 7.39.56	57.1	54.4	-8.2	41.4
681	5.12.2024 7.40.56	57.2	54.4	-8.1	41.4
682	5.12.2024 7.41.56	57.1	54.4	-8.1	41.3
683	5.12.2024 7.42.56	57.1	54.4	-8.2	41.5
684	5.12.2024 7.43.56	57.2	54.5	-8.2	41.4
685	5.12.2024 7.44.56	57.2	54.5	-8.1	41.5
686	5.12.2024 7.45.56	57.2	54.6	-8.1	41.4
687	5.12.2024 7.46.56	57.2	54.5	-8.2	41.4
688	5.12.2024 7.47.56	57.2	54.5	-8.1	41.5
689	5.12.2024 7.48.56	57.2	54.4	-8.1	41.5
690	5.12.2024 7.49.56	57.2	54.4	-8.2	41.4
691	5.12.2024 7.50.56	57.2	54.4	-8.2	41.5
692	5.12.2024 7.51.56	57.2	54.5	-8.1	41.4
693	5.12.2024 7.52.56	57.2	54.4	-8.2	41.2
694	5.12.2024 7.53.56	57.2	54.5	-8.1	41.3
695	5.12.2024 7.54.56	57.3	54.5	-8.2	41.2
696	5.12.2024 7.55.56	57.2	54.5	-8.1	41.2
697	5.12.2024 7.56.56	57.3	54.5	-8.1	41.1
698	5.12.2024 7.57.56	57.3	54.5	-8.0	41.2
699	5.12.2024 7.58.56	57.3	54.6	-8.0	40.8
700	5.12.2024 7.59.56	57.3	54.5	-8.0	41.7
701	5.12.2024 8.00.56	57.3	54.6	-7.9	41.3
702	5.12.2024 8.01.56	57.3	54.6	-7.9	41.4
703	5.12.2024 8.02.56	57.3	54.7	-8.0	41.1
704	5.12.2024 8.03.56	57.3	54.6	-8.0	41.7
705	5.12.2024 8.04.56	57.3	54.6	-7.8	41.3
706	5.12.2024 8.05.56	57.3	54.6	-7.9	41.2
707	5.12.2024 8.06.56	57.3	54.6	-7.8	41.9
708	5.12.2024 8.07.56	57.3	54.5	-7.8	41.6
709	5.12.2024 8.08.56	57.3	54.6	-7.8	41.8
710	5.12.2024 8.09.56	57.3	54.6	-7.9	41.4
711	5.12.2024 8.10.56	57.3	54.6	-7.8	41.3
712	5.12.2024 8.11.56	57.3	54.6	-7.8	41.3
713	5.12.2024 8.12.56	57.3	54.6	-7.9	41.4
714	5.12.2024 8.13.56	57.3	54.5	-7.8	41.3
715	5.12.2024 8.14.56	57.4	54.6	-7.8	41.4
716	5.12.2024 8.15.56	57.3	54.7	-7.8	41.4

ID	Date/time	BT25 MLP:ltä [°C]	BT3 paluu varaajalta MLP:hen [°C]	T ulkolämpötila [°C]	Patteriverkko menovesi [°C]
717	5.12.2024 8.16.56	57.4	54.8	-7.8	41.4
718	5.12.2024 8.17.56	57.3	54.7	-7.8	41.3
719	5.12.2024 8.18.56	57.3	54.6	-7.8	41.4
720	5.12.2024 8.19.56	57.4	54.6	-7.8	41.4
721	5.12.2024 8.20.56	57.3	54.6	-7.8	41.5
722	5.12.2024 8.21.56	57.3	54.6	-7.8	41.5
723	5.12.2024 8.22.56	57.4	54.7	-7.8	41.5
724	5.12.2024 8.23.56	57.4	54.7	-7.7	41.5
725	5.12.2024 8.24.56	57.4	54.8	-7.7	41.5
726	5.12.2024 8.25.56	57.4	54.7	-7.6	41.4
727	5.12.2024 8.26.56	57.4	54.7	-7.6	41.3
728	5.12.2024 8.27.56	57.4	54.8	-7.7	41.1
729	5.12.2024 8.28.56	57.4	54.7	-7.8	41.0
730	5.12.2024 8.29.56	57.4	54.7	-7.8	41.0
731	5.12.2024 8.30.56	57.3	54.8	-7.9	41.0
732	5.12.2024 8.31.56	57.3	54.7	-7.7	40.9
733	5.12.2024 8.32.56	57.3	54.8	-7.8	40.7
734	5.12.2024 8.33.56	57.3	54.8	-7.7	40.7
735	5.12.2024 8.34.56	57.3	54.8	-7.7	40.7
736	5.12.2024 8.35.56	57.3	54.8	-7.7	40.7
737	5.12.2024 8.36.56	57.2	54.9	-7.8	40.6
738	5.12.2024 8.37.56	57.2	54.9	-7.9	40.4
739	5.12.2024 8.38.56	57.2	54.9	-7.8	40.3
740	5.12.2024 8.39.56	57.2	54.9	-7.8	40.2
741	5.12.2024 8.40.56	57.2	54.9	-7.8	40.2
742	5.12.2024 8.41.56	57.2	54.9	-7.7	40.1
743	5.12.2024 8.42.56	57.2	54.9	-7.7	40.1
744	5.12.2024 8.43.56	57.2	54.9	-7.8	40.1
745	5.12.2024 8.44.56	57.2	55.0	-7.8	40.1
746	5.12.2024 8.45.56	57.2	55.1	-7.8	40.1
747	5.12.2024 8.46.56	57.1	55.2	-7.6	40.0
748	5.12.2024 8.47.56	57.1	55.1	-7.7	40.0
749	5.12.2024 8.48.56	57.1	55.1	-7.6	39.9
750	5.12.2024 8.49.56	57.1	55.0	-7.6	39.9
751	5.12.2024 8.50.56	57.0	55.1	-7.5	39.9
752	5.12.2024 8.51.56	57.0	55.0	-7.4	39.8
753	5.12.2024 8.52.56	57.0	55.1	-7.5	39.8
754	5.12.2024 8.53.56	57.1	55.1	-7.5	39.8
755	5.12.2024 8.54.56	57.0	55.1	-7.5	39.8
756	5.12.2024 8.55.56	57.0	55.1	-7.5	39.8
757	5.12.2024 8.56.56	57.0	55.0	-7.4	39.8
758	5.12.2024 8.57.56	57.0	55.0	-7.4	39.8
759	5.12.2024 8.58.56	57.0	55.1	-7.5	39.8
760	5.12.2024 8.59.56	57.0	55.1	-7.3	39.7

ID	Date/time	BT25 MLP:ltä [°C]	BT3 paluu varaajalta MLP:hen [°C]	T ulkolämpötila [°C]	Patteriverkko menovesi [°C]
761	5.12.2024 9.00.56	57.1	55.0	-7.1	39.7
762	5.12.2024 9.01.56	57.1	55.2	-7.2	39.6
763	5.12.2024 9.02.56	57.1	55.1	-7.1	39.6
764	5.12.2024 9.03.56	57.1	55.0	-7.0	39.6
765	5.12.2024 9.04.56	57.1	55.0	-7.0	39.6
766	5.12.2024 9.05.56	57.1	55.0	-7.1	39.6
767	5.12.2024 9.06.56	57.1	55.0	-7.0	39.6
768	5.12.2024 9.07.56	57.1	55.0	-6.9	39.6
769	5.12.2024 9.08.56	57.1	55.0	-7.0	39.6
770	5.12.2024 9.09.56	57.1	55.0	-6.9	39.5
771	5.12.2024 9.10.56	57.1	55.0	-7.0	39.5
772	5.12.2024 9.11.56	57.1	55.1	-7.0	39.5
773	5.12.2024 9.12.56	57.1	55.0	-7.0	39.5
774	5.12.2024 9.13.56	57.1	55.0	-6.8	39.6
775	5.12.2024 9.14.56	57.1	54.9	-6.8	39.7
776	5.12.2024 9.15.56	57.1	54.9	-6.8	39.7
777	5.12.2024 9.16.56	57.1	54.7	-6.8	39.7
778	5.12.2024 9.17.56	57.1	54.9	-6.7	39.7
779	5.12.2024 9.18.56	57.1	55.1	-6.8	39.7
780	5.12.2024 9.19.56	57.1	55.1	-6.8	39.7
781	5.12.2024 9.20.56	57.1	55.0	-6.8	39.7
782	5.12.2024 9.21.56	57.1	55.1	-6.7	39.6
783	5.12.2024 9.22.56	57.1	54.9	-6.7	39.6
784	5.12.2024 9.23.56	57.1	54.9	-6.6	39.6
785	5.12.2024 9.24.56	57.1	54.9	-6.7	39.6
786	5.12.2024 9.25.56	57.1	54.9	-6.7	39.6
787	5.12.2024 9.26.56	57.1	55.0	-6.6	39.6
788	5.12.2024 9.27.56	57.1	55.0	-6.6	39.6
789	5.12.2024 9.28.56	57.1	55.0	-6.6	39.7
790	5.12.2024 9.29.56	57.1	55.0	-6.5	39.7
791	5.12.2024 9.30.56	57.1	55.0	-6.5	39.7
792	5.12.2024 9.31.56	57.1	55.0	-6.5	39.7
793	5.12.2024 9.32.56	57.1	55.0	-6.4	39.7
794	5.12.2024 9.33.56	57.1	55.1	-6.3	39.6
795	5.12.2024 9.34.56	57.1	55.0	-6.4	39.6
796	5.12.2024 9.35.56	57.1	55.0	-6.5	39.6
797	5.12.2024 9.36.56	57.1	55.0	-6.4	39.6
798	5.12.2024 9.37.56	57.1	55.0	-6.4	39.7
799	5.12.2024 9.38.56	57.1	54.9	-6.4	39.7
800	5.12.2024 9.39.56	57.1	55.0	-6.3	39.7
801	5.12.2024 9.40.56	57.1	55.1	-6.4	39.8
802	5.12.2024 9.41.56	57.1	55.0	-6.3	39.8
803	5.12.2024 9.42.56	57.1	55.1	-6.3	39.8
804	5.12.2024 9.43.56	57.1	55.0	-6.4	39.8

ID	Date/time	BT25 MLP:ltä [°C]	BT3 paluu varaajalta MLP:hen [°C]	T ulkolämpötila [°C]	Patteriverkko menovesi [°C]
805	5.12.2024 9.44.56	57.1	55.0	-6.4	39.8
806	5.12.2024 9.45.56	57.1	55.0	-6.3	39.8
807	5.12.2024 9.46.56	57.1	55.0	-6.3	39.8
808	5.12.2024 9.47.56	57.1	54.9	-6.3	39.8
809	5.12.2024 9.48.56	57.1	55.0	-6.2	39.8
810	5.12.2024 9.49.56	57.1	55.0	-6.3	39.8
811	5.12.2024 9.50.56	57.2	54.9	-6.4	39.8
812	5.12.2024 9.51.56	57.1	55.0	-6.4	39.8
813	5.12.2024 9.52.56	57.1	55.0	-6.4	39.8
814	5.12.2024 9.53.56	57.2	55.0	-6.3	39.8
815	5.12.2024 9.54.56	57.2	55.0	-6.3	39.8
816	5.12.2024 9.55.56	57.2	55.0	-6.2	39.8
817	5.12.2024 9.56.56	57.2	55.0	-6.2	39.8
818	5.12.2024 9.57.56	57.2	55.0	-6.2	39.8
819	5.12.2024 9.58.56	57.2	55.0	-6.2	39.8
820	5.12.2024 9.59.56	57.2	55.1	-6.0	39.8
821	5.12.2024 10.00.56	57.2	55.0	-5.9	39.8
822	5.12.2024 10.01.56	57.2	55.1	-5.8	39.8
823	5.12.2024 10.02.56	57.2	55.1	-5.7	39.9
824	5.12.2024 10.03.56	57.2	55.0	-5.6	39.9
825	5.12.2024 10.04.56	57.2	55.0	-5.6	39.7
826	5.12.2024 10.05.56	57.2	55.1	-5.6	39.7
827	5.12.2024 10.06.56	57.2	55.0	-5.5	39.6
828	5.12.2024 10.07.56	57.2	55.0	-5.5	39.6
829	5.12.2024 10.08.56	57.2	55.0	-5.4	39.4
830	5.12.2024 10.09.56	57.2	55.0	-5.3	39.3
831	5.12.2024 10.10.56	57.2	55.1	-5.2	39.3
832	5.12.2024 10.11.56	57.2	55.2	-5.3	39.3
833	5.12.2024 10.12.56	57.3	55.1	-5.3	39.3
834	5.12.2024 10.13.56	57.2	55.1	-5.4	39.3
835	5.12.2024 10.14.56	57.2	55.1	-5.4	39.3
836	5.12.2024 10.15.56	57.2	55.1	-5.3	39.3
837	5.12.2024 10.16.56	57.0	55.1	-5.3	39.3
838	5.12.2024 10.17.56	56.8	55.1	-5.3	39.3
839	5.12.2024 10.18.56	56.7	55.1	-5.2	39.2
840	5.12.2024 10.19.56	56.6	55.2	-5.2	39.2
841	5.12.2024 10.20.56	56.5	55.2	-5.0	39.1
842	5.12.2024 10.21.56	56.4	55.1	-5.0	39.1
843	5.12.2024 10.22.56	56.4	55.1	-4.9	39.1
844	5.12.2024 10.23.56	56.5	55.1	-5.0	39.1
845	5.12.2024 10.24.56	56.6	55.2	-5.1	39.1
846	5.12.2024 10.25.56	56.6	55.1	-5.1	39.1
847	5.12.2024 10.26.56	56.6	55.1	-5.1	39.1
848	5.12.2024 10.27.56	56.6	55.1	-5.0	39.2

ID	Date/time	BT25 MLP:ltä [°C]	BT3 paluu varaajalta MLP:hen [°C]	T ulkolämpötila [°C]	Patteriverkko menovesi [°C]
849	5.12.2024 10.28.56	56.7	55.0	-4.9	39.2
850	5.12.2024 10.29.56	56.7	55.1	-4.8	39.1
851	5.12.2024 10.30.56	56.7	55.0	-4.7	39.1
852	5.12.2024 10.31.56	56.7	55.1	-4.7	39.0
853	5.12.2024 10.32.56	56.8	55.0	-4.6	38.8
854	5.12.2024 10.33.56	57.1	55.1	-4.5	38.8
855	5.12.2024 10.34.56	57.1	55.1	-4.9	38.7
856	5.12.2024 10.35.56	57.1	55.0	-5.1	38.6
857	5.12.2024 10.36.56	57.1	55.0	-4.6	38.6
858	5.12.2024 10.37.56	57.1	55.1	-4.4	38.6
859	5.12.2024 10.38.56	57.1	55.1	-4.8	38.6
860	5.12.2024 10.39.56	57.0	55.1	-4.9	38.6
861	5.12.2024 10.40.56	57.1	55.1	-5.0	38.6
862	5.12.2024 10.41.56	57.0	55.1	-5.1	38.6
863	5.12.2024 10.42.56	57.0	55.0	-5.0	38.5
864	5.12.2024 10.43.56	57.0	55.1	-4.3	38.5
865	5.12.2024 10.44.56	57.0	55.1	-4.6	38.4
866	5.12.2024 10.45.56	57.0	55.1	-4.6	38.4
867	5.12.2024 10.46.56	57.0	55.1	-4.2	38.4
868	5.12.2024 10.47.56	56.9	55.0	-4.1	38.3
869	5.12.2024 10.48.56	56.9	55.1	-4.0	38.3
870	5.12.2024 10.49.56	56.9	55.1	-3.9	38.3
871	5.12.2024 10.50.56	56.9	55.2	-3.9	38.3
872	5.12.2024 10.51.56	56.9	55.1	-4.2	38.1
873	5.12.2024 10.52.56	56.9	55.1	-4.1	38.0
874	5.12.2024 10.53.56	57.0	55.1	-4.0	37.9
875	5.12.2024 10.54.56	57.2	55.1	-3.6	37.9
876	5.12.2024 10.55.56	57.3	55.1	-3.6	37.8
877	5.12.2024 10.56.56	57.2	55.1	-4.1	37.7
878	5.12.2024 10.57.56	57.2	55.1	-4.4	37.5
879	5.12.2024 10.58.56	57.2	55.1	-4.4	37.5
880	5.12.2024 10.59.56	57.2	55.1	-4.0	37.5
881	5.12.2024 11.00.56	57.1	55.1	-3.5	37.5
882	5.12.2024 11.01.56	57.0	55.1	-3.5	37.4
883	5.12.2024 11.02.56	57.1	55.1	-3.4	37.4
884	5.12.2024 11.03.56	57.0	55.2	-3.3	37.4
885	5.12.2024 11.04.56	57.0	55.1	-3.6	37.3
886	5.12.2024 11.05.56	56.9	55.2	-4.0	37.2
887	5.12.2024 11.06.56	56.9	55.2	-3.9	37.2
888	5.12.2024 11.07.56	56.9	55.2	-3.5	37.2
889	5.12.2024 11.08.56	56.9	55.2	-3.2	37.1
890	5.12.2024 11.09.56	56.9	55.2	-3.8	37.1
891	5.12.2024 11.10.56	56.9	55.2	-3.8	37.1
892	5.12.2024 11.11.56	56.9	55.2	-3.5	37.1

ID	Date/time	BT25 MLP:ltä [°C]	BT3 paluu varaajalta MLP:hen [°C]	T ulkolämpötila [°C]	Patteriverkko menovesi [°C]
893	5.12.2024 11.12.56	56.8	55.2	-3.1	37.0
894	5.12.2024 11.13.56	56.9	55.2	-3.6	37.0
895	5.12.2024 11.14.56	56.9	55.1	-3.1	37.0
896	5.12.2024 11.15.56	57.0	55.2	-3.0	36.9
897	5.12.2024 11.16.56	57.3	55.2	-3.0	36.8
898	5.12.2024 11.17.56	57.2	55.2	-2.9	36.8
899	5.12.2024 11.18.56	57.2	55.2	-2.8	36.8
900	5.12.2024 11.19.56	57.2	55.1	-2.7	36.7
901	5.12.2024 11.20.56	57.2	55.2	-2.7	36.7
902	5.12.2024 11.21.56	57.1	55.1	-2.6	36.6
903	5.12.2024 11.22.56	57.1	55.1	-2.6	36.6
904	5.12.2024 11.23.56	57.1	55.1	-2.5	36.7
905	5.12.2024 11.24.56	57.0	55.2	-2.4	36.6
906	5.12.2024 11.25.56	56.9	55.1	-2.4	36.6
907	5.12.2024 11.26.56	56.9	55.1	-2.4	36.6
908	5.12.2024 11.27.56	56.9	55.2	-2.4	36.5
909	5.12.2024 11.28.56	56.9	55.1	-2.4	36.5
910	5.12.2024 11.29.56	56.9	55.1	-2.4	36.5
911	5.12.2024 11.30.56	56.9	55.2	-2.4	36.5
912	5.12.2024 11.31.56	56.9	55.2	-2.3	36.5
913	5.12.2024 11.32.56	56.9	55.1	-2.4	36.5
914	5.12.2024 11.33.56	56.9	55.2	-2.3	36.5
915	5.12.2024 11.34.56	56.9	55.1	-2.3	36.5
916	5.12.2024 11.35.56	56.9	55.2	-2.3	36.5
917	5.12.2024 11.36.56	56.9	55.1	-2.3	36.5
918	5.12.2024 11.37.56	57.3	55.2	-2.3	36.5
919	5.12.2024 11.38.56	57.3	55.2	-2.2	36.4
920	5.12.2024 11.39.56	57.3	55.2	-2.2	36.5
921	5.12.2024 11.40.56	57.3	55.1	-2.3	36.6
922	5.12.2024 11.41.56	57.1	55.2	-2.2	36.6
923	5.12.2024 11.42.56	57.1	55.1	-2.2	36.6
924	5.12.2024 11.43.56	57.0	55.1	-2.1	36.6
925	5.12.2024 11.44.56	57.0	55.0	-2.1	36.6
926	5.12.2024 11.45.56	57.0	55.0	-2.1	36.6
927	5.12.2024 11.46.56	57.0	55.0	-2.1	36.6
928	5.12.2024 11.47.56	56.9	55.0	-2.1	36.7
929	5.12.2024 11.48.56	56.8	55.1	-2.0	36.7
930	5.12.2024 11.49.56	56.9	55.1	-2.1	36.6
931	5.12.2024 11.50.56	56.9	55.1	-2.1	36.5
932	5.12.2024 11.51.56	56.9	55.1	-2.0	36.4
933	5.12.2024 11.52.56	56.9	55.1	-2.0	36.4
934	5.12.2024 11.53.56	56.9	55.1	-2.0	36.4
935	5.12.2024 11.54.56	57.0	55.1	-2.1	36.4
936	5.12.2024 11.55.56	57.0	55.1	-2.0	36.4

ID	Date/time	BT25 MLP:ltä [°C]	BT3 paluu varaajalta MLP:hen [°C]	T ulkolämpötila [°C]	Patteriverkko menovesi [°C]
937	5.12.2024 11.56.56	57.0	55.1	-2.0	36.4
938	5.12.2024 11.57.56	57.0	55.0	-2.0	36.4
939	5.12.2024 11.58.56	57.1	55.1	-1.9	36.4
940	5.12.2024 11.59.56	57.3	55.0	-1.9	36.4
941	5.12.2024 12.00.56	57.2	55.1	-1.9	36.4
942	5.12.2024 12.01.56	57.2	55.2	-1.9	36.4
943	5.12.2024 12.02.56	57.1	55.1	-1.9	36.3
944	5.12.2024 12.03.56	57.1	55.1	-1.9	36.3
945	5.12.2024 12.04.56	57.0	55.0	-1.9	36.3
946	5.12.2024 12.05.56	57.0	55.1	-1.9	36.3
947	5.12.2024 12.06.56	57.1	55.1	-1.8	36.3
948	5.12.2024 12.07.56	56.9	55.1	-1.8	36.3
949	5.12.2024 12.08.56	57.0	55.1	-1.9	36.3
950	5.12.2024 12.09.56	57.0	55.1	-1.9	36.3
951	5.12.2024 12.10.56	56.8	55.2	-1.8	36.3
952	5.12.2024 12.11.56	57.0	55.2	-1.8	36.3
953	5.12.2024 12.12.56	57.0	55.2	-1.8	36.3
954	5.12.2024 12.13.56	57.0	55.1	-1.7	36.3
955	5.12.2024 12.14.56	57.0	55.2	-1.7	36.3
956	5.12.2024 12.15.56	57.0	55.1	-1.7	36.3
957	5.12.2024 12.16.56	57.0	55.2	-1.7	36.2
958	5.12.2024 12.17.56	57.0	55.1	-1.7	36.2
959	5.12.2024 12.18.56	57.0	55.2	-1.7	36.2
960	5.12.2024 12.19.56	57.1	55.1	-1.7	36.3
961	5.12.2024 12.20.56	57.3	55.1	-1.6	36.3
962	5.12.2024 12.21.56	57.3	55.1	-1.7	36.3
963	5.12.2024 12.22.56	57.2	55.1	-1.7	36.3
964	5.12.2024 12.23.56	57.2	55.1	-1.7	36.3
965	5.12.2024 12.24.56	57.1	55.1	-1.6	36.3
966	5.12.2024 12.25.56	57.1	55.1	-1.6	36.3
967	5.12.2024 12.26.56	57.0	55.1	-1.6	36.2
968	5.12.2024 12.27.56	57.0	55.1	-1.6	36.2
969	5.12.2024 12.28.56	57.0	55.1	-1.6	36.2
970	5.12.2024 12.29.56	57.0	55.2	-1.6	36.2
971	5.12.2024 12.30.56	56.9	55.2	-1.6	36.2
972	5.12.2024 12.31.56	56.8	55.2	-1.6	36.2
973	5.12.2024 12.32.56	56.9	55.2	-1.6	36.2
974	5.12.2024 12.33.56	56.9	55.1	-1.6	36.3
975	5.12.2024 12.34.56	57.0	55.2	-1.6	36.3
976	5.12.2024 12.35.56	57.0	55.2	-1.6	36.3
977	5.12.2024 12.36.56	57.0	55.1	-1.6	36.3
978	5.12.2024 12.37.56	57.0	55.0	-1.6	36.3
979	5.12.2024 12.38.56	57.0	55.0	-1.5	36.2
980	5.12.2024 12.39.56	57.0	55.0	-1.5	36.2

ID	Date/time	BT25 MLP:ltä [°C]	BT3 paluu varaajalta MLP:hen [°C]	T ulkolämpötila [°C]	Patteriverkko menovesi [°C]
981	5.12.2024 12.40.56	56.9	55.1	-1.5	----
982	5.12.2024 12.41.56	----	55.1	-1.5	36.2
983	5.12.2024 12.42.56	----	----	----	----
984	5.12.2024 12.43.56	----	----	----	----
985	5.12.2024 12.44.56	----	----	----	----
986	5.12.2024 12.45.56	----	----	----	----
987	5.12.2024 12.46.56	----	----	----	----
988	5.12.2024 12.47.56	----	----	----	----
989	5.12.2024 12.48.56	----	----	----	----
990	5.12.2024 12.49.56	----	----	----	----
991	5.12.2024 12.50.56	----	----	----	----
992	5.12.2024 12.51.56	----	----	----	----
993	5.12.2024 12.52.56	----	----	----	----
994	5.12.2024 12.53.56	----	----	----	----
995	5.12.2024 12.54.56	----	----	----	----
996	5.12.2024 12.55.56	----	----	----	----
997	5.12.2024 12.56.56	----	----	----	----
998	5.12.2024 12.57.56	----	----	----	----
999	5.12.2024 12.58.56	----	----	----	----
1000	5.12.2024 12.59.56	----	----	----	----
1001	5.12.2024 13.00.56	----	----	----	----
1002	5.12.2024 13.01.56	----	----	----	----
1003	5.12.2024 13.02.56	----	----	----	----
1004	5.12.2024 13.03.56	----	----	----	----